

Ammonia-based Aeration Control (ABAC)

Project with Rivanna Sewer and Water Authority's (RWSA)
Charlottesville, Virginia

Dave Quast, Operations Specialist
Rob Haacke, Wastewater Manager



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

MPCA Minnesota Nutrient Reduction Strategy



Figure 1. Major drainage basins in Minnesota.




Figure 2. Timeline for achieving the Mississippi River milestone and goal.





Rivanna Sewer and Water Authority (RWSA)

ABAC at Moores Creek Facility

Moores Creek Water Resource Recovery Facility



WaterJAM 2024 | September 11, 2024


Building a Better World for All of Us®

Permit limits and Sampling

- Ammonia-N (May-Nov) monthly avg 2.2 mg/L weekly avg 2.7 mg/L
- Ammonia-N (Dec-Apr) monthly avg 6.4 mg/L weekly avg 8.1 mg/L
- Total Nitrogen 5.0 mg/L for the calendar year
- Total Phosphorus 0.3 mg/L for the calendar year
- Ammonia-N sampling and testing 5 days per week
- TN and TP sampling and testing 2 days per week
- Primary influent NH₄ avg 37.32 mg/L
- Final effluent NH₄ avg 0.149 mg/L



Moore's Creek Aeration



| Permit Limits | Monthly ave | Weekly Ave | Permit Limits | Calendar Year | Permit Limits | Monthly ave | Weekly Ave |
|---------------|-------------|------------|---------------|---------------|----------------------|-------------|------------|
| CBOD | 9 mg/l | 14 mg/l | Total N | 5.0 mg/l | NH3-N (May – Nov.) | 2.2 | 2.7 |
| TSS | 22 mg/l | 33 mg/l | Total P | 0.3 mg/l | NH3-N (Dec. – April) | 6.4 | 8.1 |



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Steps to implement ABAC

1. Verify accuracy of continuous monitors
2. Run model
3. Program PLC and tune controllers
4. Verify field instrumentation
5. Revise SCADA screens
6. Train users
7. Monitor
8. Summarize results



Ammonia Testing in Field: Verification of Hach monitors



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

- Bench testing with Hach 3900 and test vials in appropriate range
- Spot checks with NH4 test strips



- Recordkeeping in lab


| Date | Time 24 hour 0000-2400 | Operator | Plant Flow MGD primary | Cell sampled | MLSS % from centrifuge spin | RAS % from centrifuge spin | Ave. E2 DO | Bench NH3 | Meter NH3 | Bench NO3 | Meter NO3 | Bench pH at end | ALK @ Cell |
|------------|---------------------------|----------|---------------------------|-----------------|--------------------------------------|----------------------------------|------------|-----------|-----------|-----------|-----------|--------------------|------------|
| | | | | | | | 2.26 | 0.105 | 2.23 | 4.31 | 4.05 | | 84.9 |
| 10/10/2021 | 904 | JL | 6.75 | 5E | | 10 | 2.26 | 0.166 | 0.06 | 1 | 0.98 | 6.69 | |
| 10/10/2021 | 904 | JL | 6.75 | comb | 4.5 | | 3.87 | 0.347 | 0.2 | 4.5 | 1.96 | 2.46 | 125 |
| 10/11/2021 | 616 | DH | 9.09 | 5E | | | 1.64 | 4.5 | 7.8 | 0.606 | 0.88 | 6.63 | 96.9 |
| 10/11/2021 | 1821 | DU | 10.76 | 5E | | 10 | 3.87 | 0.041 | 0 | 2.82 | 2.66 | | |
| 10/11/2021 | 1821 | DH | 9.09 | comb | 4 | 9 | 1.64 | 0.588 | 1.3 | 5.74 | 5.8 | | 101 |
| 10/11/2021 | 616 | DU | 10.76 | comb | | | 2.67 | 2.56 | 2.51 | 4.39 | 3.88 | | 108 |
| 10/11/2021 | 1823 | DU | 9.38 | 5E | | | 1.71 | 1.37 | | 2.19 | | | 84.5 |
| 10/11/2021 | 49 | DU | 7.92 | 5E | | | 2.01 | 4.45 | 1.69 | 1.74 | 1.39 | 6.54 | |
| 10/12/2021 | 620 | CW | 10 | 5E | | | 2.67 | 0.343 | 0.43 | 1.38 | | 6.44 | 72.7 |
| 10/12/2021 | 620 | JRP | 9.38 | comb | 4 | | 1.71 | 0.105 | | 3.21 | 6.5 | | |
| 10/12/2021 | 1832 | DU | 9.38 | comb | 4 | 8 | 2.01 | 0.246 | 0.73 | 6.2 | 3.76 | | |
| 10/12/2021 | 51 | CW | 7.92 | comb | 3.5 | | 2.68 | 0.038 | 1.9 | 1.22 | 1 | 6.61 | |
| 10/12/2021 | 620 | JRP | 10 | 5E | | | 2.31 | 0.453 | 0 | 1.44 | 1.9 | 6.53 | 47.6 |
| 10/12/2021 | 1830 | JRP | 10.01 | 5E | | 9 | 2.31 | 0.048 | 0.5 | 3.1 | 2.74 | 6.12 | |
| 10/12/2021 | 22 | rm | 7.88 | comb | 4 | | 2.68 | 0.07 | 0 | | | | |
| 10/12/2021 | | | 7.88 | comb | 4 | 10 | 3.14 | 0.043 | 1.12 | | | 6.75 | 97.4 |
| | | | | comb | 4 | | 3.14 | 0.027 | 0 | | | | |
| | | | | | 4 | | 3.14 | 0.017 | 0 | | | | |
| | | | | | | | 3.11 | 0.132 | 0.085 | 1.44 | 1.07 | 6.75 | |
| | | | | | | | | | | 4.38 | | | |




Ammonia meters not great but good enough

Ion Selective Electrode (ISE) probes are less accurate at very low concentrations.

Ammonia Meter Comparison vs. Bench vs. Lab



Ammonia Meter Comparison vs. Lab



Improvement Goals - Ammonia Based Aeration Control

1. Energy Savings using instrumentation and controls
2. Better Control Strategy for Cycling Blowers
3. Better D.O. control for stability
4. Better Understanding of how the process works
5. Other savings – chemicals
6. Greenhouse Gas Reductions




Modelling



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

SIMBA Model



Evangelina Belia, Ph.D.

17% lower air flow with better D.O. control

24% lower air flow adding on ABAC

Assumes running at NH₃ limit of 2.2 mg/l

Actual desired NH₃ = 0.2 mg/l (no backsliding)



SEH's Scope and Initial Findings

Instrumentation (ammonia, DO monitors, valves actuators) must be adequate for control to work properly.

Primodal (subcontractor) limited-scope model to predict improved aeration

DO oscillated more than expected over a day

Above the DO setpoint as well

Need tight DO control for ABAC



D.O. Control Better Tuning



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Aeration System – Control Strategies

- First fix Dissolved Oxygen (DO) Control
 - Blower adjustments
 - Air valve adjustments
- Then, implement Ammonia-Based Aeration Control
- Simpler operation – easy to understand and teach



Superstar Programmer – SEH Senior Control Systems Engineer



Ted Bottelberghe



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Preliminary Evaluation



Successful Stabilization of:

- DO concentration close to the setpoint
- Valve position
- Blower flow rate

Implementation

- Programmed April 2022
- Started May 2022
- Tuned by July 2022
- Flow Meter Logic Corrections
- De-spiking Program Modifications
- Most Open Valve Logic
- Blower Staging Program Improvements

BLOWER STAGING PROGRAM

BLOWER STAGE STATUS:
RUNNING STAGE 3

START NEW BLOWER FIRST OR STOP PREVIOUS BLOWER FIRST:
START FIRST, THEN STOP

Blowers Desired Speed: 94 %

BLOWER STEP UP DELAY SP: 30 Sec.

Countdown to Step Up: 30 Sec.

BLOWER STEP DOWN DELAY SP: 30 Sec.

Countdown to Step Down: 20 Sec.

BLOWER STAGE UP SPEED SP: 98.0 %

BLOWER STAGE DOWN SPEED SP: 85.0 %

BLOWER STEP UP INITIAL SPEED SP: 85.0 %

BLOWER STEP DOWN INITIAL SPEED SP: 95.0 %




After Tuning – Despiking program,




MC AERATION AVG TOTAL D.O.


Before Tuning



After Tuning



Timeline – ABAC implementation




January 2022 – Baseline – typical D.O. control


On-line Monitors

Before ABAC implementation

Higher ammonia concentrations correspond to lower D.O. levels



July 2024 – ABAC Control



ABAC Implementation


- Programming
- Tuning
- Verifying
- Training – (SCADA screens)



ABAC Strategy

- Use ammonia concentration feedback to control the DO levels in aeration basin
- Operator sets ammonia setpoint and program updates the DO setpoints to control ammonia based on feedback from an ammonia monitor in the basin effluent channel
- Include explanation of how the system works on the operator screen





OVERVIEW

BLOWERS

BLOWER CONTROL

BASINS

TRENDS

AMMONIA BASED AERATION CONTROL

AUTO **MANUAL** **MANUAL**

Aeration Basin Effluent Channel Ammonia:
CV: mg/L
SCL_AIT_AB401C_AMMONIA

CALCULATED DO SP: mg/L
CALCULATED ZONE 2 DO SP: mg/L

AMMONIA SP: mg/L
UPDATE PERIOD SP: Sec
GAIN SP:
ZONE 2 DO OFFSET SP: mg/L
MAXIMUM DO SP: mg/L
MINIMUM DO SP: mg/L
ZONE 2 MINIMUM DO SP: mg/L

Ammonia based aeration control
When ABAC is set to automatic, controller adjusts the DO setpoints for all basins to control ammonia to setpoint. Bumping controller: Every update period setpoint, the controller calculates the difference between ammonia and ammonia setpoint, then multiplies the difference by the gain setpoint and adds the result to the DO setpoint. When ammonia is above setpoint, DO setpoints increase. when ammonia is below setpoint, DO setpoints decrease. All basins' zone 2s can be ran at a lower DO setpoint than all zone 1s. Zone 2 DO offset setpoint sets the difference.
The DO setpoint is limited.
High DO to all zones is limited by the maximum DO setpoint. Low DO to all basins is limited by the minimum DO setpoint. Zone 2 basins have an additional zone 2 minimum DO setpoint to account for the offset SP.

Splitter Box Ammonia: mg/L
SCL_AIT_FB401_AMMONIA

AIR VALVE SETPOINTS FOR D.O. CONTROL

| SERVICE | VALVE | PROCESS VARIABLE | ENABLED | SETPOINT | |
|-----------------|-----------|------------------|---------|-----------------------------------|------|
| BASIN 1, ZONE 1 | MOV-AB211 | AIT-AB414 | YES | <input type="text" value="1.75"/> | mg/L |
| BASIN 1, ZONE 2 | MOV-AB212 | AIT-AB415 | YES | <input type="text" value="1.00"/> | mg/L |
| BASIN 2, ZONE 1 | MOV-AB221 | AIT-AB424 | YES | <input type="text" value="1.75"/> | mg/L |
| BASIN 2, ZONE 2 | MOV-AB222 | AIT-AB425 | YES | <input type="text" value="1.00"/> | mg/L |
| BASIN 3, ZONE 1 | MOV-AB231 | AIT-AB434 | YES | <input type="text" value="1.75"/> | mg/L |
| BASIN 3, ZONE 2 | MOV-AB232 | AIT-AB435 | YES | <input type="text" value="1.00"/> | mg/L |
| BASIN 4, ZONE 1 | MOV-AB241 | AIT-AB444 | YES | <input type="text" value="1.75"/> | mg/L |
| BASIN 4, ZONE 2 | MOV-AB242 | AIT-AB445 | YES | <input type="text" value="1.00"/> | mg/L |
| BASIN 5, ZONE 1 | MOV-AB251 | AIT-AB454 | YES | <input type="text" value="1.75"/> | mg/L |
| BASIN 5, ZONE 2 | MOV-AB252 | AIT-AB455 | NO | <input type="text" value="1.00"/> | mg/L |

AIR VALVE SETPOINTS FOR AIRFLOW CONTROL

| SERVICE | VALVE | PROCESS VARIABLE | ENABLED | SETPOINT | |
|----------------------|-----------|------------------|---------|----------------------------------|------|
| BASIN 1, RE-AERATION | MOV-AB213 | FDIT-AB413 | NO | <input type="text" value="300"/> | SCFM |
| BASIN 2, RE-AERATION | MOV-AB223 | FDIT-AB423 | YES | <input type="text" value="300"/> | SCFM |
| BASIN 3, RE-AERATION | MOV-AB233 | FDIT-AB433 | NO | <input type="text" value="300"/> | SCFM |
| BASIN 4, RE-AERATION | MOV-AB243 | FDIT-AB443 | YES | <input type="text" value="300"/> | SCFM |
| BASIN 5, RE-AERATION | MOV-AB253 | FDIT-AB453 | NO | <input type="text" value="300"/> | SCFM |

MIXED LIQUOR DISTRIBUTION CHANNEL
MOV-AB201 FDIT-AB401 SCFM

MINIMUM AIRFLOW SETTINGS

| SERVICE | VALVE | FLOW TUBE | MINIMUM AIR SETPOINT | MINIMUM AIR MOD | |
|--------------------------|-----------|------------|----------------------------------|-------------------------------------|------|
| BASIN 1, ZONE 1 | MOV-AB211 | FDIT-AB411 | <input type="text" value="300"/> | <input type="text" value="360.00"/> | SCFM |
| BASIN 1, ZONE 2 | MOV-AB212 | FDIT-AB412 | <input type="text" value="150"/> | <input type="text" value="150.00"/> | SCFM |
| BASIN 1, RE-AERATION | MOV-AB213 | FDIT-AB412 | <input type="text" value="65"/> | | SCFM |
| BASIN 2, ZONE 1 | MOV-AB221 | FDIT-AB421 | <input type="text" value="300"/> | <input type="text" value="360.00"/> | SCFM |
| BASIN 2, ZONE 2 | MOV-AB222 | FDIT-AB422 | <input type="text" value="150"/> | <input type="text" value="210.00"/> | SCFM |
| BASIN 2, RE-AERATION | MOV-AB223 | FDIT-AB423 | <input type="text" value="65"/> | | SCFM |
| BASIN 3, ZONE 1 | MOV-AB231 | FDIT-AB431 | <input type="text" value="300"/> | <input type="text" value="320.00"/> | SCFM |
| BASIN 3, ZONE 2 | MOV-AB232 | FDIT-AB432 | <input type="text" value="150"/> | <input type="text" value="150.00"/> | SCFM |
| BASIN 3, RE-AERATION | MOV-AB233 | FDIT-AB433 | <input type="text" value="65"/> | | SCFM |
| BASIN 4, ZONE 1 | MOV-AB241 | FDIT-AB441 | <input type="text" value="300"/> | <input type="text" value="360.00"/> | SCFM |
| BASIN 4, ZONE 2 | MOV-AB242 | FDIT-AB442 | <input type="text" value="150"/> | <input type="text" value="150.00"/> | SCFM |
| BASIN 4, RE-AERATION | MOV-AB243 | FDIT-AB443 | <input type="text" value="65"/> | | SCFM |
| BASIN 5, ZONE 1 | MOV-AB251 | FDIT-AB451 | <input type="text" value="300"/> | <input type="text" value="360.00"/> | SCFM |
| BASIN 5, ZONE 2 | MOV-AB252 | FDIT-AB452 | <input type="text" value="150"/> | <input type="text" value="210.00"/> | SCFM |
| BASIN 5, RE-AERATION | MOV-AB253 | FDIT-AB453 | <input type="text" value="65"/> | | SCFM |
| MINIMUM AIRFLOW DEADBAND | | | <input type="text" value="30"/> | | SCFM |

NOTE: MINIMUM AIRFLOW SETPOINTS ARE BIASED BY "SWING" MIXERS

OVERVIEW

BLOWERS

DO CONTROL

BASINS

TRENDS

BLOWER STAGING PROGRAM

BLOWER STAGE STATUS:

RUNNING STAGE 3

START NEW BLOWER FIRST OR
STOP PREVIOUS BLOWER FIRST:

START FIRST, THEN STOP

Blowers Desired Speed: 97.5 %

BLOWER STEP UP DELAY SP: 300 Sec.

Countdown to Step Up: 300 Sec.

BLOWER STEP DOWN DELAY SP: 420 Sec.

Countdown to Step Down: 420 Sec.

BLOWER STAGE UP SPEED SP: 99.1 %

BLOWER STAGE DOWN SPEED SP: 88.3 %

BLOWER STEP UP INITIAL SPEED SP: 90.0 %

BLOWER STEP DOWN INITIAL SPEED SP: 91.0 %

NOTE: Blowers' speed range is 88 - 100%

PURGE MODE

PURGE MODE STATUS: NOT ACTIVE

PURGE MODE SPEED SP: XXXXXX %

PURGE MODE DURATION SP: 0 Sec.

PURGE MODE VALVE POSN SP: XXXXXX %

PURGE START: PURGE

CANCEL PURGE: CANCEL

Time Remaining in Purge: 0 Sec.

Purge mode:
Purge mode is initiated manually.
When initiated, blowers selected for purge step start and run at purge mode speed setpoint.
All available aeration valves open to the purge mode valve position setpoint.
Purge mode runs for purge mode duration setpoint or until canceled.
Upon completion/cancelation, blowers return to last step.

BLOWER STEP ASSIGNMENT

| | BLOWER 1 5,925 | BLOWER 2 3,950 | BLOWER 3 5,925 | BLOWER 4 3,950 | BLOWER 5 5,925 |
|--------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| STEP 1: | NO | NO | NO | YES | NO |
| STEP 2: | NO | NO | NO | NO | YES |
| STEP 3: | NO | NO | NO | YES | YES |
| STEP 4: | NO | NO | YES | NO | YES |
| STEP 5: | YES | NO | NO | YES | YES |
| STEP 6: | YES | YES | NO | YES | YES |
| STEP 7: | YES | YES | NO | YES | YES |
| PURGE: (STEP 8) | NO | NO | YES | NO | YES |

Blower step assignment.
Note: program ignores unavailable blowers assigned to steps.
It starts and runs all available blowers assigned to the current step.
Caution: If an assigned blower becomes available, it will automatically start.
A blower is available if it is in remote, in auto, enabled, and not failed.

Most-Open-Valve Selector

| SERVICE | VALVE | |
|--------------------|-----------|--------|
| | AB251 | |
| BASIN 1, ZONE 1 | MOV-AB211 | AB211 |
| BASIN 1, ZONE 2 | MOV-AB212 | AB212 |
| BASIN 2, ZONE 1 | MOV-AB221 | AB221 |
| BASIN 2, ZONE 2 | MOV-AB222 | AB222 |
| BASIN 3, ZONE 1 | MOV-AB231 | AB231 |
| BASIN 3, ZONE 2 | MOV-AB232 | AB232 |
| BASIN 4, ZONE 1 | MOV-AB241 | AB241 |
| BASIN 4, ZONE 2 | MOV-AB242 | AB242 |
| BASIN 5, ZONE 1 | MOV-AB251 | AB251 |
| BASIN 5, ZONE 2 | MOV-AB252 | AB252 |
| MOST OPEN POSN SP: | | 75.0 % |

Most open valve:
Choose one basin aeration valve to be most open.
The selected valve is fixed at the most open position setpoint.
The selected valve's DO controller remains active and calculates desired airflow setpoint for the valve.
Note: Larger most open position setpoint settings result in all valves opening more and lower header pressure.

| | |
|-----------------|-----------|
| AVERAGE HP: | 173 HP |
| TOTAL HP: | 347 HP |
| AVERAGE D.O.: | 0.29 mg/L |
| TOTAL AIR FLOW: | 9496 SCFM |
| AVERAGE SPEED: | 98.0 % |

| EQUIPMENT STATE COLORS: | |
|-------------------------|-----------------|
| RUN / OPEN | = RED |
| OFF / CLOSED | = GREEN |
| FAIL / ALARM | = PURPLE |
| UNAVAILABLE | = YELLOW |
| OUT OF SERVICE | = YELLOW |
| WARNING | = RED |
| FUTURE | = GRAY |
| WHITE | = NOT MONITORED |
| DUTY | = GREEN |
| STANDBY | = BLUE |
| OUT OF RANGE | = BLACK |





Blower staging program:
When desired speed is greater or equal to the blower stage up speed setpoint, the step up timer is started.
If desired speed remains above the stage up speed setpoint for the blower step up delay setpoint, then the blower stage increases by one. When the Desired Speed is less than or equal to the blower stage down speed setpoint, the step down timer is started. If desired speed remains below the stage down speed setpoint for the blower step down delay setpoint, then the blower stage will decrease by one.
Blower start/stop sequencing is determined by start mode: Select start first, then stop mode to start any newly selected blowers first then stop any not selected blowers upon a stage step. Select stop first, then start mode to stop all non-selected blowers first then start newly selected blowers. Newly selected blowers always start sequentially from blower 1 to blower 5.
Special Stages:
Step 0 is the power fail stage. Program goes to this stage when power loss occurs. When power is restored, blower staging program is activated and blowers begin to stage up starting at stage 1.
Stage 8 is purge mode. When purge mode is activated, selected blowers start and run at purge mode speed setpoint. When purge time expires or when purge is canceled, blowers return to previous step.

Monitoring




WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®



Ammonia Setpoint Changes





Electric Use (per lb ammonia removed)
reduced by 11%



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Rivanna Blower kW Before and After ABAC




Wow:
Caustic Use reduced by 55%



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®


Caustic Use gallons/day



Caustic gallons /day= 55% sodium hydroxide (\$3.35/ gallon) diluted to about 27.5%



Supplemental Carbon Micro-C gallons/ day



Total Nitrogen

Nutrient Exchange Program


Nitrogen credits sold



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Pounds Per Year Nitrogen



Benefits

Lower D.O. and less fluctuation in DO concentration

Reduced mechanical wear and tear on the equipment (less blower cycling – smoother transitions)

Simpler system – easier to understand – instructions on SDADA screen

More resilient system – adjustable for upsets and outages




Recovery from Phosphorous and Nitrogen Spikes




WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

Total Phosphorous in
Plant effluent mg/l



Total Nitrogen in
Plant effluent mg/l






Planned Power Outage 4-3-24

0700 - 1100



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®



Recovery from Loss of Signal Communications



WaterJAM 2024 | September 11, 2024

Building a Better World for All of Us®

SYSTEM ALARM HELP TREND REPORTS DISPLAY OVERVIEW PRINT CONTROL PANEL

BLOWER CONTROL PARAMETERS DO_VALVE_CONTROL

D.O. & MIN AIR PARAMETERS

CELL I CELL H CELL G CELL F CELL E CELL D CELL C CELL B CELL A

MOV-AB221 D.O. CONTROL

VALVE ENABLED

D.O. SETPOINT **2.00 mg/L**

D.O. READING **0.91 mg/L**

VALVE POSITION **22.0 %**

IN AUTO

REMOTE AUTO

EXIT

For Help, press F1

MIXED LIQUOR DISTRIBUTION CHANNEL

AB-213 AB-413 300 SCFM

AB-223 AB-423 0 SCFM

AB-233 AB-433 0 SCFM

AB-243 AB-443 0 SCFM

AB-201 AB-401 404 SCFM

AB-253 AB-453 267 SCFM

AB-211 AB-411 1336 SCFM

AB-221 AB-421 1485 SCFM

AB-231 AB-431 1476 SCFM

AB-241 AB-441 1355 SCFM

AB-251 AB-451 1997 SCFM

BLOWERS

BASINS MIXERS AND NRCY

AERATION BASIN 1

AIR HEADER BASINS 1 & 2

AERATION BASIN 2

BASINS ANALYZERS

AERATION BASIN 3

AIR HEADER BASINS 3 & 4

AERATION BASIN 4

PER LIMIT 23.00 %

OVER LIMIT 7.00 %

AIR HEADER MIXED LIQUOR DISTR CHNL

AERATION BASIN 5

AIR HEADER BASIN 5

| Date | Time | Alarm ID | State | Ack | Message |
|---------|-------------|-----------------------|-------|-----|---|
| 02/3/22 | 07:42:34 AM | UV_CH3_BANKA_LAMP_FLT | ALARM | N | UV Channel 3 Bank 1 Lamp Fault Alarm MC UV System |
| 02/3/22 | 07:42:28 AM | UV_MINOR_ALM | ALARM | N | MC UV System in Minor Alarm State |
| 02/3/22 | 07:42:28 AM | UV_CH3_BANKB_LAMP_FLT | ALARM | N | UV Channel 3 Bank 2 Lamp Fault Alarm MC UV System |

19 Mar 23 07:42 Toggle Setup Ack All Reset Delete Ack and Reset



Summary Table

| Chemical Savings | | | | | |
|----------------------|-------------------------------|-----------------------------------|----------------------------------|---------------|-----------------|
| | \$/gallon | usage before ABAC gpd | usage after ABAC gpd | % improvement | \$ Savings/year |
| Caustic 25% solution | \$1.68 | 550 | 250 | 54.5% | \$183,200 |
| Micro-C | \$2.85 | 322 | 355 | -10.2% | -\$34,300 |
| Electric Savings | | | | | |
| | \$/kWhr | usage before ABAC kWh/year | usage after ABAC kWh/year | | \$ Savings/year |
| Blowers | 0.0972 | 2,076,120 | 1,900,920 | 9.5% | \$17,000 |
| MCAWRRF (Plant) | 0.0972 | 9,040,000 | 7,916,223 | 12.4% | \$109,231 |
| Nutrient Trading | | | | | |
| | \$/CREDIT (Upper James River) | Nitrogen credits before ABAC 2021 | credits after ABAC Nitrogen 2023 | | \$ Savings/year |
| Total Nitrogen | \$0.80 | 112,506 | 104,420 | -7.1% | -\$6,500 |
| Net Annual Savings | | | | | \$161,800 |



Comparison with Other ABAC Studies

| Location Utility Year Average Flow Study | Ontario CA Ontario MUC 2018 - 2019 25 MGD Full Scale | Westfield MA Westfield Public W 2019 3.4 MGD Pilot Scale | Nansemond VA HRSD 2013 - 2015 30 MGD Full Scale | Charlottesville VA Rivanna (RWSA) 2022- 2024 10 MGD Full Scale |
|--|--|--|---|--|
| | % improvement | % improvement | % improvement | % improvement |
| Caustic | | 20% | | 55% |
| Supplemental Carbon | | | 51% | -10% |
| Electricity (kWhr) | 9% | 10 – 15% | 10% | 11% |
| Total N | | | 6.0 -> 7.6 mg/l | 2.2 - > 3.5 mg/l (-7% 2023) |
| Net Savings \$/year | | | \$300,000/yr | \$161,800/yr |
| Return On Investment | 4 years | 6.7 years | | < 1 year |
| Reference | Impact of Ammonia-Based Aeration Control (ABAC) on Energy(mdpi.com) | 1cityofwestfield.org | Nansemond HRSD ABAC 2014 | |



Summary



Blower energy savings

- ~9% = 175,200 KWh/year

Greenhouse Gas reductions^{1,2,3}

- + 60 tons/year CO₂
- + 160 tons/year CO₂
- + ? tons/year N₂O



Chemical Savings

- 150 gallons per day of 55% caustic = 55,000 gallons per year



Cost Savings

- Electric \$17,000 / yr
- Caustic \$183,200 / yr
- Micro – C (\$34,300)/yr
- N Credits (6,500)year

Overall Savings

\$161,800 / year

Greenhouse Gas Reduction

**220+ tons per year
CO₂ equivalent**

¹https://www.epa.gov/system/files/documents/2022-04/ghg_emission_factors_hub.pdf

²[ghg-emission-factors-hub-2024.xlsx \(live.com\)](#)

³[Chloralkali process - Wikipedia](#)

Recommendations

- Continue to operate the DO minimum setpoints at 1.00 to 1.25 mg/L. Most recently, the setpoints have been 1.25 mg/L in the first zone and 0.75 mg/L in the second zone.
- Continue to operate with the effluent ammonia setpoint at 1.5 - 2.0 mg/L.
- Add feed forward control with new ammonia probe at the inlet of aeration tanks (Fall 2024)





Rob Haacke,
RWSA



Lina Belia,
Primodal



Amy Prok, PM
SEH



Dave Quast
SEH



Ted Bottelberghe
SEH



Thad Webb
SEH

ABAC Project Team Questions?

BQZJQ

